

# Utility MACT Working Group



Hg: Accounting for  
Variation/Error

OAQPS/ESD  
July 9, 2002



# Data



- 80 plants
- 3 runs
- 240 data points



# Analysis

- Used SAS VARCOMP (Variance Component) procedure
- Analyzed the following model

$$Y_{ij} = \mu + F_i + P_j + e_{ijk}$$



$$Y_{ij} = \mu + F_i + P_j + e_{ijk}$$

■ Where

- $Y_{ij}$  is the observation for the  $j$ th plant using the  $i$ th fuel for the  $k$ th run
- $\mu$  is the overall mean,
- $F$  is a fixed effect for the fuel type (e.g. lignite)
- $P$  is a random effect due to a plant,
- $e$  is an error term with all remaining sources of variation



# Results



- Variance component due to plants
  - 45.94
- Variance component due to error
  - 13.29



# Application

- Variance due to plant for a 3-run mean
  - 19.74
- Variance due to error for a 3-run mean
  - 4.44
- T-values for 90, 95, and 99 percent, one-tailed confidence interval
  - 1.2816
  - 1.645
  - 3.323



# Application (cont.)

---

- Mean of best 12% for each fuel type
  - Bituminous 0.087
  - Sub-bituminous 0.724
  - Lignite 2.251



## Application (cont.)

- Limit will be a one-sided confidence interval of the means of the best 12% percent for each fuel type

$$Limit = \bar{X}_{best\ 12\% \text{ for fuel}} + T_{\alpha, df > 30} \cdot S$$

$$S = \sqrt{S_{plant}^2 + S_{error}^2}$$



# Application (cont.)

- Resulting potential floor levels that incorporate variability (lb/TBtu)

Fuel	90% limit	95% limit	99% limit
Bituminous	5.782	7.397	10.409
Sub-bituminous	6.419	8.034	11.046
Lignite	7.946	9.561	12.573

